

PFAS	PFOA	PFOS	PFHxS	PFNA	HFPO-DA	PFBS	Risk Index
	ng/L (ppt)						
Public Drinking Water – NR 809 maximum contaminant levels	4	4	10	10	10	(2000 as part of index)	1 (see note 1)
Groundwater – proposed NR 140	enforcement standard	4	10	10	10	2000	NA
	preventive action limit (PAL)	0.4	0.4	1	1	200	NA
Surface water – drinking water use (see note 2)	waters with drinking water use	20	8	NA	NA	NA	NA
	all other waters	95	8	NA	NA	NA	NA

1. In addition to maximum contaminant levels for PFOA, PFOS, PFHxS, PFNA and HFPO-DA (Gen X chemicals) there is a PFAS index MCL for PFHxS, PFNA, HFPO-DA and PFBS) In that index a value of 2000 ng/L is used for PFBS. The MCL values are used for the rest. The PFAS index MCL is set equal to 1.

2. Lake, Michigan, Lake Superior and Lake Winnebago have drinking water designated uses.

NA = not applicable